



Windowworld Leicester LTD
Unit G Belgrave Industrial Centre
Ross Walk
Leicester LE4 5HH

BS EN 14531 – 1:2006 + A1:2010 Annex ZA

Calibre Residential & Double Doors
WW CAL D002
Ability to Release External Pedestrian Doors in Escape
Routes

Dangerous Substances	None
Load Bearing Capacity Safety Devices	Pass
Thermal Transmittance	< 4.7
Ability to Release	Pass